



Certificate of Compliance

Certificate: 2316536 (LR 49184-3)

Master Contract: 162842

Project: 70046601

Date Issued: November 17, 2015

Issued to: Mersen USA Newburyport-MA, LLC

374 Merrimac St
Newburyport, MA 01950-1998
USA
Attention: Marla Miller

The products listed below are eligible to bear the CSA Mark shown



Ramana Tangirala

Issued by: Ramana Tangirala

PRODUCTS

CLASS 1422 01 - FUSES - Special Type

- **Type "SU" (or Alternate Cat No. "MI5SU25V") followed with current rating**, Cartridge fuses, non-renewable, Size 5 mm by 20 mm, 1.25 to 12.5A, 250V ac.

APPLICABLE REQUIREMENTS

CSA Std. C22.2 No. 248.1 - Low-Voltage Fuses □ □ Part 1: General Requirements

CSA Std. C22.2 No. 248.14 - Low-Voltage Fuses □ □ Part 14: Supplemental Fuses