



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE190315006352-A1

Product Fuse-holder

Applicant MERSEN USA NEWBURYPORT-MALLC
374 MERRIMAC ST NEWBURYPORT MA 01950, USA

Type/Model US3J*

Technical data Un: AC600V,DC600V; In:30A;
I1:100kA(600VAC),50kA(,600VDC); 1P,2P,3P; IP20

This is to certify that, on the basis of the tests undertaken as per Report No. 00901-CE2018CQC0315-009808-1-A1,00901-CE2018CQC0315-009808-2-A1, the submitted sample(s) of the above item complies with:

EN 60269-1:2007+A1:2009;HD 60269-2:2013

and fulfills testing requirements of the European Directive:

Low Voltage Directive (LVD):2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

Valid from: Jun.18,2021

Valid until: Jun.18,2024

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE
Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

CE 0011523