



Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer	Mersen France SB S.A.S		
Address	15, Rue de Vaucanson, 69720, Saint Bonnet De Mure, France		
Place of Production	Nolam Tunisia Rue De Nabeul Lot No.4, Zone Industrielle de M'Ghira, Tunisia		
Type	CMS 14 – 690 V: 50 A max CMS 22 – 690 V: 125 A max		
Description	Fuse holders, 690 V, with or without accessories.		
Application	Industrial application for Switch and Control gear		
Specified Standard	IEC60269-1; 2006 60269-2-1; 2006 60269-2; 2006 60947-1; 2007 60947-3; 2008		
Ratings		CMS 14	CMS 22
	Voltage:	690 V	690 V
	Fuse:	50 A max	125 A max
	Poles:	1 to 4 and N, 1 + N and 1 to 4 and N, 1 + N and 3 + N poles 3 + N pôles	1 to 4 and N, 1 + N and 1 to 4 and N, 1 + N and 3 + N poles 3 + N pôles

237 Brownlow Avenue, Suite 200, Dartmouth, NS.
B3B2C7, Canada

Yongchang Cai

Electrical & Control - Senior Specialist to
Lloyd's Register Canada Limited
A member of the Lloyd's Register group

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



Type Approval Certificate

Accessories	Fuse holders CMS 14 and CMS 22
Degree of Protection	IP 20
Other Conditions	Installation of this equipment for marine applications is to be in accordance with current Lloyd's Register Rules and Regulations.

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register Canada Limited of any modification or changes to the equipment in order to obtain a valid Certificate.

Previous Version: 19/30005

The Design Appraisal Document LR2435311TA and its supplementary Type Approval Terms and Conditions form part of this Certificate.

237 Brownlow Avenue, Suite 200, Dartmouth, NS.
B3B2C7, Canada

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

