

# Certificate of Compliance

**Certificate Number:**

UL-US-L76491-2113-01019891-4

**Report Reference:**

E76491-19891010

**Issue Date:**

2025-04-01

Issued to:

**MERSEN FRANCE SB S A S**  
**15 RUE DE VAUCANSON ST BONNET DE MURE 69720**  
**France**

This certificate confirms that representative samples of:

**JFHR2 - Special-purpose Fuses - Component**

**See Addendum Page for Product Designation(s).**

Have been evaluated by UL in accordance with the component requirements in the Standard(s) indicated on this Certificate. UL Recognized components are incomplete in certain constructional features or restricted in performance capabilities and are intended for installation in complete equipment submitted for investigation to UL LLC.

**UL 248-1, 4th Ed., Issue Date: 2022-10-24, UL 248-13, Edition 3, Issue Date 2022-03-31**

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Recognized Component Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Recognized Component Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Recognized Component Mark on the product.



A handwritten signature in black ink, appearing to read 'David Piecuch'.

David Piecuch  
UL Mark Certification Program Owner

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

# CERTIFICATE OF COMPLIANCE

**Certificate number** UL-US-L76491-2113-01019891-4  
**Report reference** E76491-19891010  
**Date** 2025-04-01

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

## Component special purpose fuses, semiconductor protection fuses

**Model(s):** 5 URD 233 PLAF 3600, 5,5 URD 233 PLAF 3200, 6 URD 233 PLAF 2200, 6 URD 233 PLAF 2500, 6 URD 233 PLAF 2800

## Special purpose semi-conductor protection fuses, with or without indicators

**Model(s):** A 050 U or UR, A 055U or UR, A 060 U or UR, A 065 U or UR, A 070 U or UR followed by B, C, D, E or F, followed by 30, 31, 32, 33, 232 or 233, followed by additional suffix designations, followed by ampere rating, may be followed by additional suffix designations

**Model(s):** 4 UR, 4,5 UR, 5 UR, 5,5 UR, 6 UR, 6,6 UR, 6,9 UR followed by D, E or F, B, C, followed by 30, 31, 32, 33, 232 or 233, followed by additional suffix designations, followed by ampere rating, may be followed by additional suffix designations

**Model(s):** A 0600 URD32 followed by suffixes, 1101 to 1250A, 600Vac, IR 600Vac-200kA, note these ratings all have reinforced terminals.



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

# Certificate of Compliance

**Certificate Number:**

UL-CA-2418229-1

**Report Reference:**

E76491-19891010

**Issue Date:**

2025-04-01

Issued to:

**MERSEN FRANCE SB S A S**  
**15 RUE DE VAUCANSON ST BONNET DE MURE 69720**  
**France**

This certificate confirms that representative samples of:  
**JFHR8 - Special-purpose Fuses Certified for Canada - Component**

**See Addendum Page for Product Designation(s).**

Have been evaluated by UL in accordance with the component requirements in the Standard(s) indicated on this Certificate. UL Recognized components are incomplete in certain constructional features or restricted in performance capabilities and are intended for installation in complete equipment submitted for investigation to UL LLC.

**CSA C22.2 No. 248.1:22, 4th Ed., Issue Date: 2022-10-24, CSA C22.2 No. 248.13:22, 3rd Ed., Issue Date: 2022-03-31**

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Recognized Component Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Recognized Component Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Recognized Component Mark on the product.



David Piecuch  
UL Mark Certification Program Owner



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

# CERTIFICATE OF COMPLIANCE

Certificate number UL-CA-2418229-1  
Report reference E76491-19891010  
Date 2025-04-01

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

## Component special purpose fuses, semiconductor protection fuses

**Model(s):** 5 URD 233 PLAF 3600, 5,5 URD 233 PLAF 3200, 6 URD 233 PLAF 2200, 6 URD 233 PLAF 2500, 6 URD 233 PLAF 2800

## Special purpose semi-conductor protection fuses, with or without indicators

**Model(s):** A 050 U or UR, A 055U or UR, A 060 U or UR, A 065 U or UR, A 070 U or UR followed by B, C, D, E or F, followed by 30, 31, 32, 33, 232 or 233, followed by additional suffix designations, followed by ampere rating, may be followed by additional suffix designations

**Model(s):** 4 UR, 4,5 UR, 5 UR, 5,5 UR, 6 UR, 6,6 UR, 6,9 UR followed by D, E or F, B, C, followed by 30, 31, 32, 33, 232 or 233, followed by additional suffix designations, followed by ampere rating, may be followed by additional suffix designations

**Model(s):** A 0600 URD32 followed by suffixes, 1101 to 1250A, 600Vac, IR 600Vac-200kA, note these ratings all have reinforced terminals.



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.